

ADDENDUM NO. 2

Date: May 2, 2022

CITY OF FOLSOM CITY HALL & COMMUNITY CENTER ROOF REPAIR PROJECT

Bids to be received: **2:00 P.M., Tuesday, May 10th, 2022**

This Addendum is applicable to the work designated herein and shall be a part of and be included in the Contract. The Contractor shall acknowledge his/her acceptance of this addendum by initialing the line designated 'Acknowledge Addenda' at the end of the Sealed Proposal Form. All other provisions of the Project Manual shall remain in effect.

Item #1. Clarification: Sheathing shall be installed directly on trusses. All exposed surfaces to be painted to match existing.

Item #2. Clarification: The existing Gladding McBean Interlocking Tile style is Lincoln, and the color is Blended Red. Any new tile used are to exactly match the existing tile. Gladding McBean is aware of this project and has confirmed the availability of the tile style and color.

This Addendum, including this page, consists of 1 page.

This concludes Addendum #2.